DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/24/2013 FORM APPROVED OMB NO. 0938-0391

NAME OF PROVIDER OR SUPPLIER SURGICAL CENTER OF NEW ALBANY MAT Mathematical Program	STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	A. BUILDING 01 - MAIN BUILDING 01 B. WING		(X3) DATE SURVEY COMPLETED R 07/06/2011		
SURGICAL CENTER OF NEW ALBANY (A4) 0 SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY PULL RESOLATORY ORLS DESTRIPTION PROMATION) [K 000] INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 05/13/11 was conducted by the Indiana State Department of Health in accordance with 42 GFR 416.44(b). Survey Date: 07/06/11 Facility Number: 100274040A Surveyor: Mark Bugni, Life Safety Code Specialist At this PSR survey, Surgical Center of New Albany was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 GFR Subpart 416.44(b), Life Safety Tode (Life) Code (Life) (Life) Safety Food (Life) S		15C0001005						
PREFIX TAGE REGULATORY OR LSC IDENTIFYING INFORMATION PREFIX TAGE CROSS-REFERENCED TO THE APPROPRIATE CROSS-REFERENCED TO THE APPROPRIATE					2201 GREEN VALLEY RD			
A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 05/13/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 416.44(b). Survey Date: 07/06/11 Facility Number: 005386 Provider Number: 15C0001005 AIM Number: 100274040A Surveyor: Mark Bugni, Life Safety Code Specialist At this PSR survey, Surgical Center of New Albany was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 21, Existing Ambulatory Health Care Occupancies. This one story facility was determined to be of Type V (000) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 07/07/11.	PREFIX	(EACH DEFICIENCY MUST BE PRECEDED BY FULL		PREF	PREFIX (EACH CORRECTIVE ACTION S TAG CROSS-REFERENCED TO THE A		OULD BE	COMPLETION
Code Recertification Survey conducted on 05/13/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 416.44(b). Survey Date: 07/06/11 Facility Number: 005386 Provider Number: 15C0001005 AIM Number: 100274040A Surveyor: Mark Bugni, Life Safety Code Specialist At this PSR survey, Surgical Center of New Albany was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety Tom Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 21, Existing Ambulatory Health Care Occupancies. This one story facility was determined to be of Type V (000) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 07/07/11.	{K 000}	INITIAL COMMENTS		{K 000}				
APODATORY DIRECTOR'S OR PROVIDED/SLIPBLIED REDRESENTATIVE'S SIGNATURE TITLE (VS) DATE		A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 05/13/11 was conducted by the Indiana State Department of Health in accordance with 42 CFR 416.44(b). Survey Date: 07/06/11 Facility Number: 005386 Provider Number: 15C0001005 AIM Number: 100274040A Surveyor: Mark Bugni, Life Safety Code Specialist At this PSR survey, Surgical Center of New Albany was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 21, Existing Ambulatory Health Care Occupancies. This one story facility was determined to be of Type V (000) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors. Quality Review by Robert Booher, Life Safety						
	ABODATODY		(SLIDDI IED DEDDESENTATIVE'S SIGNATUR	F		TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.